

Shangqiu Quality Supervision and Inspection Test Center
 in Henan Province
Test Report

● 塑料油 Plastic Oil

Items	Testing Project	Measurement Unit	Standard Requirement	Test Results	Notes
1	Gross calorific value	kJ/l @20 degrees C	GB/T 384-1981	10500	
2	Density	kg/l @20 degrees C	SH/T 0604-2000	0.821	
3	Viscosity	mm ² /s @50 degrees C	GB/T 11137-1989	3.1	
4	Water content	% v/v,max	GB/T 260-1977	0.06	
5	Flash point (PMCC)	degrees C	GB/T 261-2008	38	
6	Sulphur,% min and max	%	GB/T 17040-2008	0.005	
7	Ash	%	GB/T 508-1985	0.02	